


[Back to List](#)

[Save PDF](#)



TOSOT

Central Air Conditioning Heat Pump (HP)

Singlezone Non-Ducted, Wall Placement

AHRI Cert #: **210485377**

Outdoor Unit Model #: **TWH09ATCXB-D3DNA3AO**

Indoor Model #: **TWH09ATCXB-D3DNA3AI**

🔥 Maximum Heating Capacity (Btu/h) @5°F: **7,400**

🔥 Rated Heating Capacity (Btu/h) @47°F: **10,000**

❄️ Rated Cooling Capacity (Btu/h) @95°F: **9,100**

[Basic View](#) ⓘ

[Advanced Data - Sizing for Heating](#)

Information Tables

Brand	TOSOT
Series	
Ducting Configuration	Singlezone Non-Ducted, Wall Placement
AHRI Certificate #	210485377
Outdoor Unit Model #	TWH09ATCXB-D3DNA3AO
Indoor Model #	TWH09ATCXB-D3DNA3AI
Indoor Unit Type	Mini-Splits
Furnace Model #	
EER	11.3
SEER	19.5
HSPF (Region IV)	10
EER2	11.3
SEER2	19.5
HSPF2 (Region IV)	8.8
HSPF2 (Region V)	6.8
ENERGY STAR V6.1	
ENERGY STAR V6.1 Cold Climate	
ENERGY STAR V5.0	
Federal Tax Credit Eligibility North	
Federal Tax Credit Eligibility South	
Capacity Maintenance (Rated 17°F/Rated 47°F)	60%
Capacity Maintenance (Rated 5°F/Rated 47°F)	%
Capacity Maintenance (Max 5°F/Rated 47°F)	74%

Performance Specs

Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated	Max
Cooling	95°F	80°F	Btu/h	2,000	9,100	10,300
			kW	0.16	0.81	1.1
			COP	3.66	3.29	2.74
Cooling	82°F	80°F	Btu/h	2,400	-	11,500
			kW	0.11	-	0.75
			COP	6.39	-	4.49
Heating	47°F	70°F	Btu/h	2,200	10,000	12,000
			kW	0.15	0.78	1.06
			COP	4.3	3.76	3.32
Heating	17°F	70°F	Btu/h	1,500	6,000	9,000
			kW	0.25	0.65	1.25
			COP	1.76	2.71	2.11
Heating	5°F	70°F	Btu/h	1,200	-	7,400
			kW	0.26	-	1.2
			COP	1.35	-	1.81
Heating	-13°F	70°F	Btu/h	1,000	-	5,500
			kW	0.27	-	1.1
			COP	1.09	-	1.47

Variable Capacity ✓

Integration


Connectivity

Operational Diagnostics

Refrigerant R410A

Sold In USA, Canada

Heating/Cooling Capacity Graph



Highcharts.com

Pan Heater

Type Integrated

Input Power (W) 72W±5%

Operation (1)T outer ring≤1°C; (2)From beginning of defrost to ending of defrost

Additional Heat Pump Images



Related Products



NORTHEAST ENERGY EFFICIENCY PARTNERSHIPS, INC.

Main address:
24 School Street, 2nd Floor
Boston, MA 02108-4314

Remittance address:
500 Unicorn Park Drive, Suite 300, 3rd floor
Woburn, MA 01801

Copyright ©2023

[EmailNEEP](#) | [Terms of Use & Privacy Policy](#)